



Request for Quotation

245 NE 30 Rd.

6027.1-3

Great Bend KS, 67530

Date: December 19, 2010

<p>Vendor: Rosemount: Puffer-Sweiven www.Puffer.com Yokogawa: www.techstaris.com Honeywell: dlamance@wilsonmohr.com Other Qualified Vendors</p>	<p>Notes: Don Day (day@letton-hall.com) Eric Kelner (kelner@letton-hall.com)</p>
--	---

Quantity	Description	Unit Price	Extension
4	<p>Transmitter, Static Pressure indicating, -200 to +400 in., H2O-calibrated range, two ½ in. electrical entries w/plugs, 4-20 mA digital Hart Smart output. 316 ss isolating diaphragm, glass-filled PTFE o'rings, silicone-filled, LCD display, Calibration datasheet, fitted with two valve co-planer-manifold. 2 in. "pipe-stand mounting bracket."</p> <p>Tag # 1-PIT-100 1-PIT-200 2-PIT-100 2-PIT-200</p>		
4	<p>"Transmitter, temperature indicating, with 0-150 Deg. F calibrated range, ½ in. electrical entry, 4-20 mA Hart smart output, 304 ss thermal-well for ¾ in. Pipe entry, 2-1/2 in. "U" length with 4-wire 100 Ohm RTD, LCD transmitter display."</p> <p>Tag # 1-TIT-100 1-TIT-200 2-TIT-100 2-TIT-200</p>		